

STILLE-DEROSSETT-HALE SINGLE STATE CONSTRUCTION CODE ACT (EXCERPT)
Act 230 of 1972

125.1504h Installation of manual fire alarm box required in schools; exception.

Sec. 4h.

A school building that has a vestibule is not required to have a manual fire alarm box installed within the vestibule if a manual fire alarm box is located within 5 feet of the interior door of the vestibule.

History: Add. 2019, Act 20, Eff. Sept. 5, 2019

Popular Name: Act 230

Popular Name: Uniform Construction Code