

FUEL OIL (EXCERPT)
Act 319 of 1929

125.566 Installation of inside tanks.

Sec. 16.

Where it is impractical to bury tanks, the chief inspector of the department of buildings and safety engineering may allow them to be installed inside of a building when completely incased in 12 inches of concrete and 6 inches of sand.

History: 1929, Act 319, Imd. Eff. May 28, 1929 ;-- CL 1929, 2623 ;-- CL 1948, 125.566